

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160277, Building Permit - Commercial  
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, June 02, 2017

Partial Correction  
1 Misc

RATED DOOR HEAD ASSEMBLIES PER DETAILS 11/A7.03 & 12/A7.03:

OPENING 2-100.1: FRAMING & LINER BOARD @ INSIDE(W) FACE;  
1ST LAYER 5/8" TYPE X GWB; 2ND LAYER 5/8" TYPE X GWB;

OPENING 4-100.1: FRAMING & LINER BOARD @ INSIDE(W) FACE;  
1ST LAYER 5/8" TYPE X GWB AT WALLS/BULKHEAD; 2ND LAYER 5/8" TYPE X GWB AT WALLS/BULKHEAD; FRAMING & SHAFT LINER BOARD AT CEILING; 1ST LAYER 5/8" TYPE X GWB AT CEILING;  
2ND LAYER 5/8" TYPE X GWB AT CEILING;

OPENING 2-200: FRAMING & LINER BOARD @ INSIDE(W) FACE;  
1ST LAYER 5/8" TYPE X GWB; 2ND LAYER 5/8" TYPE X GWB;

OPENING 2-204: WALL FRAMING & LINER BOARD @ INSIDE(W) FACE; WALL 1ST LAYER 5/8" TYPE X GWB; WALL 2ND LAYER 5/8" TYPE X GWB; **LID FRAMING & LINER BOARD OK TO COVER AFTER FIRE-STOPPING IS COMPLETED;**

FRAMING & LINER BOARD @ N WALL OF B208;

**Comments:**