
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20161367, Public Works Infrastructure Permit - Commercial
JOHN KNOX VILLAGE - MEADOWS
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Driveway Inspection	Steve Robbins	Partial	Friday, June 02, 2017

Informational

- 1 The driveway approach on Moore St. has been formed and rock was compacted. They are set up for a less than 2% slope for the sidewalk, told them they needed to use kcmmb mix for the approach and curbs. Steve Robbins 06/02/2017 3:52 PM

Comments:
