

Temporary Certificate of Occupancy

Permit #: PRRES20162246
Address: 1333 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Monday, June 05, 2017
Inspected By: Khanh Nguyen
Expiration Date: 7/5/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Monday, June 05, 2017

Corrective Action Required:

1	Misc	-DECK PIERS WERE NOT INSPECTED
		-EXPOSE SEWER TRACER BOX
		**BRING THE TRACER BOX TO ABOVE GRADE LEVEL
		-INSTALL A RECEPTACLE WITHIN 25 FT OF THE AC UNIT
		***FIX THE GROOUND FAULT TRIPPING THE RECEPTACLE