

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162330, Building Permit - Residential
Address: 1308 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Monday, June 05, 2017

Corrective Action Required

1	Misc	-PROVIDE CS-PF WALL AT REAR DINING AREA CORNER **INSTALL THE STRAP AT THE INNER SIDE OF THE CS-PF WALL. SEE DRAWING
---	------	---

***OK TO ROCK

Comments: