

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20170703, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Monday, June 05, 2017

Partial Correction		
2	Misc	RETAINING WALL AT SOUTH NOT PRESENTLY READY FOR INSPECTION

Comments:OK TO POUR WHEN READY REMAINING SECTIONS OF CONCRETE TIE BEAM, GRADE BEAM + INTEGRAL PIER CAPS