

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Monday, June 05, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY PVC UNDER-SLAB ELECTRICAL
CONDUIT: ONE 3" + ONE 1" FROM ELEVATOR EQUIPMENT ROOM
TO MDP LOCATION; LOWER LIFT CONDUIT COMPLETE AT MDP
LOCATION; ONE 2" PVC FROM EXIT UNDER BLDG NE SLAB
EXTENDED N INTO POOL EQUIPMENT AREA; **CONDUIT AT
SUBGRADE THROUGHOUT POOL AREA;**

Comments: