



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20160125	Date:	June 06, 2017
Project Title:	SAINT LUKES HOSPITAL - WOUND CARE - MOB 3RD FLOOR	Applicant:	
Location:	20 NE SAINT LUKES BLVD, Unit:330, LEES SUMMIT, MO 64086	SIMPLEXGRINNELL LP P O BOX 3042 BOCA RATON, FL 33431	
Type of Work:			
Occupancy Group:	I-2	SIMPLEXGRINNELL LP	
Description:	INTERIOR ALTERATIONS TO SUITE 330 FOR OUTPATIENT CLINIC - INSTALL 2 HYPERBARIC CHAMBERS, FOUR EXAM ROOMS, DR/NURSE OFFICES	P O BOX 3042 BOCA RATON, FL 33431	Primary: (913) 894-0010 Ext: CORP
Construction Type:	Type IA		
Map Page:	175X		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(Information purposes)

Testing of the new installation will be required prior to the final occupancy inspection. To schedule the testing contact the fire department at 816-969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.