



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

June 06, 2017

LANGSFORD DEVELOPMENT INC
616 SW 3RD ST
LEES SUMMIT, MO 64063

Permit No: PRCOM20171833
Project Title: SUMMIT DENTAL
Project Address: 622 SW 3RD ST, Unit:M, LEES SUMMIT, MO 64063
Parcel Number: 61330168900000000
Location: RNG-31 TWP-47 SEC-06 PT SW 1/4 DAF: BEG AT A PT 1150' W OF SE COR SD SW 1/4 TH N 28' M/L TO N ROW LI OF 3RD ST & TRU POB TH CONT N 220' TH E 130' TO SW COR LOT 58 ROBIN HILLS TH N 125' TO S ROW LI OF
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: EXPAND EXISTING DENTIST OFFICE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Post the suite designation on the exterior of all doors leading into the space. Address shall be readable from the roadway.

2. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED: (verified at inspection)

Provide two 2A-10BC fire extinguishers. One to be mounted toward the rear of the space and one to be mounted toward the front of the space.

3. Exit/emergency lighting

ACTION REQUIRED: Do away with the exit/emergency light fixture located in the storage/workroom.

4. Door operations

ACTION REQUIRED: No keyed locks on the egress side of an exit. (verified at inspection)

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.