



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161204	Date:	June 06, 2017
Project Title:	TRANE US - INTERIOR ALTERATIONS - MEZZANINE	Applicant:	
Location:	2724 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064	FALCON FIRE SPRINKLER LLC 1239 A CLAY ST N KANSAS CITY, MO 64116	
Type of Work:		Primary: (816) 734-0018	
Occupancy Group:	S-2		
Description:	STRUCTURAL STEEL MEZZANINE IN WAREHOUSE AREA		

*drawings are in plan review file

Construction Type: Type IIB (Unprotected)

Map Page: 175R

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(verified at inspection)

The existing fire sprinkler system riser shall be current with all required maintenance and servicing. A current service tag shall be posted on the systems riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.