

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Partial	Tuesday, June 06, 2017

Partial Correction
1 Misc

POOL SHELL RE-BAR BONDED TO PERIMETER BONDING RING
WITH LEADS TO BEYOND SHELL POUR

Partial Correction
2 Misc

**POOL DECK REINFORCING MESH BONDED; READY FOR DECK
POUR**

Comments: