

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170078, Building Permit - Residential
Address: 1321 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Wednesday, June 07, 2017

Corrective Action Required

1	Misc	-ENGINEER TO ADDRESS DAMAGED JOIST BELOW MASTER TOILET
		-BLOCK JOISTS PER PLAN IN BASEMENT
		***OK TO ROCK

Comments: