

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170195, Building Permit - Residential

Address: 2213 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822215 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822217 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822211 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Wednesday, June 07, 2017

Corrective Action Required

1	Misc	2211 missing bath fan 1st floor install block over furnace/kitchen wall between joist. -support 3" dwv over kitchen -2213 notched floor joist over kitchen for 3" dwv. firestop and seal heat duct to 2nd floor thorough plywood center 2 units. -2215 seal rigde at firewall each side
---	------	--

Electrical Service Inspection - Residential	Mark Harding	Passed	Wednesday, June 07, 2017
--	--------------	--------	--------------------------

Comments: