

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

June 07, 2017

SDC ENGINEERING
5907 RAYTOWN TFWY
RAYTOWN, MO 64133

Permit No: PRCOM20171531
Project Title: NAILTOPIA
Project Address: 3500 SW MARKET ST, LEES SUMMIT, MO 64082
Parcel Number: 70500031400000000
Location: SUMMITCREST PLAZA LOT 1--- LOT 1
Type of Work: CHANGE OF TENANT
Occupancy Group:
Description: TENANT FINISH FOR NAIL SALON

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.

Planning and Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

2. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:(verified at inspection)

Post the numeric address on the exterior of all doors leading into the suite. Address shall be readable from the roadway.

4. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

Testing of any modifications done to the fire alarm system is required prior to the final occupancy inspection. To schedule a test contact the fire department at 816-969-1300.

Building Plan Review

Reviewed By: Joe Frogge

Rejected

CODES ADMINISTRATION

1. 2012 IBC 1014.2 Egress through intervening spaces. Egress through intervening spaces shall comply with this section. Item 4. Egress shall not pass through kitchens, storage rooms, closets or spaces used for similar purposes. (See code section for additional items and exceptions)

Action required: Designate specific use of "Back Room"
6/7/17 - clarified in letter. Path to exit to remain clear.

3. 2012 IBC 1006.1 Illumination required. The means of egress, including the exit discharge, shall be illuminated at all times the building space served by the means of egress is occupied.

Action required: Provide emergency lighting at exterior sides of exit doors.

6/7/17 - emergency lighting must have battery backup per IBC 1006.3, item #3. Revise design.

Licensed Contractors

Reviewed By: Joe Frogge

Rejected

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed Electrical and Mechanical contractors.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.