

PUBLIC WORKS ENGINEERING DIVISION

Punch List

Date: Thursday, June 08, 2017

To: LEVEL BUILDERS LLC
P O BOX 29145
PARKVILLE, MO 64152
Fax # <NO FAX NUMBER>
SWAMI HOTELS LLC
1024 SW WANAMAKER RD
TOPEKA, KS 66604
Fax # <NO FAX NUMBER>

Re: Certificate of Substantial Completion for:

Project Title: Holiday Inn Express (1201 NW Innovation Pkwy.)FDP

Permit Number: PRPWFC20160041

Permit Type and Work Class: Public Works Infrastructure Permit - Commercial,
Development-Complete

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813. Failure to complete all items will result in a freeze of building permits until all items are corrected and a Certificate of Final Acceptance is issued.

PUNCH LIST CORRECTIONS:

1. Replace the cracked sidewalk on the ADA ramp, one section.

2. Establish vegetation around the property in the ROW.

3. All trash and debris needs to be cleaned up and removed from property.

Permit Holder
(Signature & Date)

Steve Robbins, Field Engineering Inspector
(Signature & Date)

Original: Public Works Inspections File

Copy:

Developer

Public Works Development Engineering Manager

Contractor

Design Engineer / Architect