

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171226, Building Permit - Residential
Address: 611 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Friday, June 09, 2017

**Comments: OK TO POUR WHEN READY WALL FOOTINGS & ISOLATED POST FOOTINGS. UFER
GROUNDING JUMPER IS IN PLACE AT NORTH WALL.**