

CODES ADMINISTRATION

Residential Plan Review

June 09, 2017

NICK ZVACEK CONSTRUCTION LLC 1009 INDUSTRIAL DR PLEASANT HILL, MO 64080 (816) 213-7204

Permit No: PRRES20171896 Plan Name: ANDERSON 2

Project Address: 1820 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

Parcel Number: 69720051900000000

Location: NAPA VALLEY 2ND PLAT---LOT 95

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW SINGLE FAMILY

FINISHED BASEMENT COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Planning and Codes Administration (816) 969-1200

Plot Plan Review Reviewed By: Nick Lightner Rejected

- 1. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.
- *Please provide in a bubble " AS-GRADED PLOT PLAN IS REQUIRED PRIOR TO SODDING"
- 2. Spot elevations and/or drainage flow arrows shall be provided throughout the lot.

*Can you please double check the slope from the rear, west and east of the lot. Also the NE corner of the house to the NE corner of the lot and also the NW corner of the house tot he NW corner of the lot. Make sure it is carrying at least 2% or more.

Residential Plan Review Reviewed By: Jonathon Hilton Not Required

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.

Residential Area:							
Residential, Living Area		1547					
Residential, Un-Finished basements Residential, Finished basements Residential, Decks Residential, garage		1007 540 168 660					
				Residential, Living Area 2		667	
				Roofing Material		Number of Bathrooms	4.5
				Number of Bedrooms	5	Number of Stories	2
Number of Living Units	1	Total Living Area	2754				
Sewer Connection Fee	16						