

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20170703, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Friday, June 09, 2017
 Partial Correction			
1      Misc	OK TO COVER WHEN READY <b>UNDER-SLAB PVC SANITARY DRAIN, WASTE, &amp; VENT PIPING AT: SPACES 1A212, 216, 217, 221, 227 + MAIN DRAIN LINE FROM THEM TO BLDG DRAIN;</b>		
 NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.			
 Partial Correction			
2      Misc	<b>OK TO COVER WHEN READY SECTIONS ON ROOF DRAIN STORM PIPING: ON (H.6) FROM (15.6) TO CONNECTION AT MAIN STORM DRAIN LINE AT (17.5);</b>		
 <b>Underslab Plumbing Inspection - Commercial</b>			
John Borns	Partial	Friday, June 09, 2017	
 Partial Correction			
1      Misc	OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: SPACES 1A212, 216, 217, 221, 227 + MAIN DRAIN LINE FROM THEM TO BLDG DRAIN;		
 NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.			
 Partial Correction			
2      Misc	OK TO COVER WHEN READY SECTIONS ON ROOF DRAIN STORM PIPING AT:		

**Comments:**