

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162985, Building Permit - Residential

Address: 2092 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822094 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822096 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822090 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Monday, June 12, 2017

Corrective Action Required

1	Misc	2096 attic access lid gfcı 2nd floor doesnt work exterior issues.
---	------	--

Comments: