PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rated Assembly John Borns Partial Tuesday, June 13, 2017

Inspection

Partial Correction

1 Misc OK TO COVER WHEN READY COMPONENTS OF RATED WALL

ASSEMBLIES: 106; 107; 110; 117; 118; 127; 128; 135-138; 142; 143; 145; 147; 148; 157; 158; [104; 105; 108; 109; 113; 119; 122;

Partial Correction

2 Misc OK TO TAPE, MUD, & FIRE-STOP WHEN UL P522 RATED CEILING

ASSEMBLIES AT SPACES: 104-108; 110; 117; 118; 121-123; 125-129; 132; 135; 136-138; 141- 144; 147; 148; 154-158; 159;

161; 162; [108, 113; 115;

Partial Correction

3 Misc PP1 WALLS: SHAFT LINER LAYER APPROVED; OK TO APPLY 5/8"

TYPE X AT OPPOSITE FACE AT C113 WEST & C157 EAST;

Underground Electrical John Borns

Inspection - Commercial Partial Tuesday, June 13, 2017

Partial Correction

1 Misc OK TO POUR WHEN READY LIGHT POLE BASES AT FOLLOWING

LOCATIONS NUMBERED ON SITE PLAN IN PERMIT PRINT SET: #1

THRU #15;

Partial Correction

2 Misc OK TO COVER WHEN READY TRENCHED PVC CONDUIT: FROM

L.P.#2 ONE 1" TO 80' WEST + ONE 3/4" TO 28' WEST CONN TO EXSTG; ONE 1" FROM PL#2 TO 45' NE FOR BL; ONE 1" ~80'

ACROSS FRONT ENTRANCE FROM BL TO BL; ONE 3/4" FROM LP#7 ~110' NW FOR BL; ONE 1" FROM PL#7 NORTH 20' TO Q-BOX

LOCATION; ONE 1" FROM Q-BOX LOCATION NW TO BL LOCATION EAST OF ENTRANCE CANOPY; GROUND ROD FOR LP#7 LAID IN CONDUIT TRENCH DUE TO ROCK CONDITIONS; FROM L.P.#10 TO #11 TO #12; #13 TO #9 TO #10; FROM #12 TO #14 TO #15; **FROM** #6 TO 15' WEST

Comments: