

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162993, Building Permit - Residential

Address: 2133 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822135 SW TIMBERTRACE LN, LEES
SUMMIT, MO 640822137 SW TIMBERTRACE LN, LEES SUMMIT, MO 640822131 SW
TIMBERTRACE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Wednesday, June 14, 2017

Corrective Action Required

1	Misc	all -cover plates in kitchen each unit 2133 garage step over 7 3/4" 2135 seal garage from dwelling 2137 move water line in garaeg to access.
---	------	---

Comments: