

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20162603, Building Permit - Residential
Address: 308 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Wednesday, June 14, 2017

Corrective Action Required

1	Misc	-OBTAIN IRRIGATION PERMIT -RE-GRADE REAR OF THE HOUSE, REQUIRED TO HAVE MINIMUM 6" CLEARANCE FROM SIDING TO GRADE AND 6" OF FALL AWAY FROM THE FOUNDATION WITHIN THE FIRST 10' -MAX FUSE FOR AC IS 40 AMP -INSTALL SECURITY SCREWS BOTH BACK DOORS.
---	------	--

Comments: