

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20162603  
**Address:** 308 SE MILL CREEK DR, LEES SUMMIT, MO 64063  
**Inspected On:** Wednesday, June 14, 2017  
**Inspected By:** Mike CopelandMike Copeland  
**Expiration Date:** 7/14/2017 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Wednesday, June 14, 2017

Corrective Action Required:

1	Misc	-OBTAIN IRRIGATION PERMIT -RE-GRADE REAR OF THE HOUSE, REQUIRED TO HAVE MINIMUM 6" CLEARANCE FROM SIDING TO GRADE AND 6" OF FALL AWAY FROM THE FOUNDATION WITHIN THE FIRST 10' -MAX FUSE FOR AC IS 40 AMP -INSTALL SECURITY SCREWS BOTH BACK DOORS.
---	------	--

<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Temporary C of O	Wednesday, June 14, 2017
---	---------------	------------------	-----------------------------

Corrective Action Required:

1	Misc	-OBTAIN IRRIGATION PERMIT -RE-GRADE REAR OF THE HOUSE, REQUIRED TO HAVE MINIMUM 6" CLEARANCE FROM SIDING TO GRADE AND 6" OF FALL AWAY FROM
---	------	---

THE FOUNDATION WITHIN THE FIRST 10'