

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, June 14, 2017

Partial Correction

1 Misc

WALLS AND CEILING AT LINK CORRIDOR A111 OK TO COVER
EXCEPT SE 10' OF SW WALL; **FIRE-BLOCK HORIZONTAL AT TOP
PLATE AND CALL FOR RE-INSPECTION**

Comments: