

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20170703, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Thursday, June 15, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING AT: SPACES 1A212, 216, 217, 221, 227 + MAIN DRAIN LINE FROM THEM TO BLDG DRAIN; **DWV PIPING NORTH OF (14)**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Partial Correction

2 Misc

OK TO COVER WHEN READY SECTIONS ON ROOF DRAIN STORM PIPING: ON (H.6) FROM (15.6) TO CONNECTION AT MAIN STORM DRAIN LINE AT (17.5); **COMPLETE NORTH OF (14);**

Underslab Electrical Inspection - Commercial	John Borns	Partial	Thursday, June 15, 2017
---	------------	---------	-------------------------

Partial Correction

1 Misc

NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT MATERIAL & WORKMANSHIP AT: **1A209/1A217; 1A221/222;**

Comments: