

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial
Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, June 15, 2017

Partial Correction
1 Misc

RATED ASSEMBLIES AT STAIRWELLS:
OK TO COVER AT SOUTH STAIRWELL: LEVEL ONE 1ST LAYER 5/8"
TYPE X MOLD-TOUGH GWB; **PRE-ROCK 1ST LAYER AT BACKSIDE TRUSS-JOIST BAYS;**
OK TO COVER AT NORTH STAIRWELL: LEVEL ONE 1ST LAYER 5/8"
TYPE X MOLD-TOUGH GWB; **PRE-ROCK 1ST LAYER AT BACKSIDE TRUSS-JOIST BAYS;**

Partial Correction
2 Misc

RATED ASSEMBLIES AT ELEVATOR SHAFT. OK TO COVER AT:
PRE-ROCK 1ST LAYER AT BACKSIDE TRUSS-JOIST BAYS;

Comments: