

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161761, Building Permit - Commercial
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, June 15, 2017

Partial Correction		
1 Misc		INTERIOR SHEAR WALL AT SOUTH STAIRWELL -- OK TO COVER AT: 1ST FLOOR;

Rated Assembly Inspection	John Borns	Partial	Thursday, June 15, 2017
--------------------------------------	------------	---------	-------------------------

Partial Correction		
1 Misc		RATED ASSEMBLIES AT STAIRWELLS: OK TO COVER AT SOUTH STAIRWELL: BASEMENT 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB; BASEMENT PRE-ROCK 1ST LAYER AT BACKSIDE JOIST BAYS;

Partial Correction		
2 Misc		RATED ASSEMBLIES AT ELEVATOR SHAFT: PRE-ROCK AT BACKSIDE JOIST BAYS AT BASEMENT;

Comments: