

RECEIVED

MAY 24 2017

Development Services

CODE MODIFICATION REQUEST

BUILDING/STRUCTURE NAME: SUMMIT CENTER - ABSOLUTE LIAIR & NAILS -
PREMISE ADDRESS: 236 NW QLOHAM PARYWAY
PERMIT NUMBER (if applicable): PRCOM 20170850
OWNER'S NAME: CUIZZY REAL ESTATE, 2700 NE KENDALLWOOD PKWY 816-414-5200 GLADSTONE, MO. 6419
TO: Director of Codes Administration
In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or
more provisions of the code. The following articulates my request for your review and action.
(NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY)
WE PERVEST THAT AN EXISTING ELECTRICAL PANEL RE
ALLOWED TO REMAIN IN AN EXISTING TOILET ROOM.
WE WILL INSTALL A NEW DISCONNECT SWITCH AHEAD
OF THAT PANEL AT THE EXTERIOR OF THE BUILDING
(-REF. NEC SECTION 230.70 (A)(Z))
SUBMITTED BY:
NAME: JEFF SCHEDER / SCHARHAL ARCH. () OWNER MOWNER'S AGENT
ADDRESS: 6247 BROOKSIDE BLIO. #204 TELEPHONE 816 - 656 - 5055
CITY, STATE, ZIP: KC, MO. 64-113 SIGNATURE: SIGNATURE:
MANAGER OF INSPECTIONS ACTION RECOMMEND APPROVAL () DENIAL
SIGNATURE: 1/10 CORRECT DATE: 5-24-17
SIGNATURE: 11, 12 Goods DATE: 5 - 1 / DATE:
,
DIRECTOR OF CODES ADMINISTRATION ACTION: () APPROVED () DENIED
SIGNATURE: DATE:
MARK DUNNING, DIRECTOR OF CODES ADMINISTRATION
COMMENTS:
A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE
Installing Service Disconnect on the outside of the b makes this application compliant with section 230.70.
as a state of the section 720 To
Makes this application compliant with the M.C.
19. C.