



## FIRE DEPARTMENT

### PLAN REVIEW CONDITIONS

June 16, 2017

YAEGER ARCHITECTURE  
7780 WEST 119TH STREET  
OVERLAND PARK, KS 66213

Permit No: PRCOM20171899  
Project Title: SUMMIT WOODS - FACADE REMODEL  
Project Address: 1700 NW CHIPMAN RD, LEES SUMMIT, MO 64081  
Parcel Number: 51700031300000000  
Location: CHIPMAN HWY 50--- LOT 12  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group:  
Description: EXTERIOR REMODEL - FACADE

*The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.*

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

#### **Building Plan Review**

**Reviewed By: Joe Frogge**

**Approved**

#### **Fire Plan Review**

**Reviewed By: Joe Dir**

**Approved with Conditions**

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED:( verified at inspection)

Any addressing that is effected by the store front demolition shall be replaced. All addressing shall be readable from the roadway.

#### 2. Coverings:

ACTION REQUIRED: Provide fire resistance certification of awnings material at inspection.

NFPA 2013 section 5000 32.4.3

Awnings and canopies shall be permitted to have a combustible covering that meets the flame propagation performance criteria of NFPA 701, standards methods of fire tests for flame propagation of textiles and films, or that meets the requirements of class A in accordance with chapter 10 NFPA 5000

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***