

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20161367, Public Works Infrastructure Permit - Commercial  
JOHN KNOX VILLAGE - MEADOWS  
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

**Inspection Item:**

| <b>Inspection:</b>     | <b>Inspector:</b> | <b>Outcome:</b> | <b>Date:</b>          |
|------------------------|-------------------|-----------------|-----------------------|
| PW-Driveway Inspection | Steve Robbins     | Passed          | Friday, June 16, 2017 |

**Informational**

1 The driveway approach on Moore St. has been formed and rock was compacted. They are set up for a less than 2% slope for the sidewalk, told them they needed to use kcmmb mix for the approach and curbs. Steve Robbins 06/02/2017 3:52 PM

**Informational**

2 The driveway approach has been installed on Moore st. and has passed inspections. All approaches have passed. Steve Robbins 06/16/2017 11:42 AM

**Comments:**