

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, June 16, 2017

Partial Correction
1 Misc

OK TO PRE-ROCK DESIGNATED WALL SECTIONS AT SHOWERS AT:
203 SW; 206; 211; 212; 214; 215; 217; 222; 224;

303; 304; 305; 310; 311; 312; 314; 315; 317; 322; 323; 324;

403; 404; 405; 411; 415; 422; 423; 424;

Partial Correction
2 Misc

OK TO COVER WHEN READY FRAMING OF WALLS AND CEILINGS +
SYSTEMS TO BE ENCLOSED AT SPACES:

204; 205; 211; 212; 215; 217; 222; 223; 224; 214; **[310; 312
EXCEPT MECH CLOSET(FIRE-BLOCKING);**

**311 NOT READY: CHECK & COMPLETE HOLD-DOWNS +
FIRE-BLOCK AT MECH CLOSET**

Partial Correction
3 Misc

**OK TO INSTALL GWB CEILING AT CORRIDOR SPACES:
201; 216; 219; 221; 225;**

**Rated Assembly
Inspection**

John Borns	Partial	Friday, June 16, 2017
------------	---------	-----------------------

Partial Correction
1 Misc

OK TO COVER WHEN READY PRE-ROCK GWB AT SHOWERS AT:
204; 205; 211; 212; 214; 215; 217; 222; 223; 224;

304; 305; 310; 311; 312; 314; 315; 317; 322; 323; 324;

404; 405; 411; 412; 414; 415; 417; 422; 423; 424;

Partial Correction

2 Misc

**OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS
AT: 201; 216; 219; 221;**

Partial Correction

3 Misc

**OK TO COVER WHEN READY 5/8" TYPE X GWB AT UNIT FACE OF
STAIRWELL WALLS AT: 214;**

Partial Correction

4 Misc

**OK TO COVER WHEN READY FRAMING + SHAFT LINER BOARD AT
STAIRWELLS -- WELL SIDE + UNIT SIDE AT: 102; 202; 203; 213;
302; 303; 313; 314;**

Comments: