

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit: PRRES20170595, Building Permit - Residential
Address: 1341 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed.

Inspection:	Inspector:	Outcome:	Date:
Erosion/Sediment Control	Bart Reese	Needs repair	June 20, 2017

Corrective Action Required

Site lacks erosion control - silt fence down on the east perimeter of the lot, dirt on the street (Gateway Dr.)