

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20170703, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Retaining Wall Inspection	John Borns	Passed	Wednesday, June 21, 2017

**Comments: OK TO COMPLETE FORMING AND POUR WHEN READY C.I.P. RETAINING WALL ON (12.1).
PREP AND POUR OF SLAB-ON-GRADE TO BE INSPECTED BY SPECIAL INSPECTOR.**