

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Wednesday, June 21, 2017

Corrective Action Required
1

Comments: MONUMENT SIGN BASE PREP'D FOR POUR WITH #4 RE-BAR AT 12" C/C E/W T&B.