

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161750, Building Permit - Commercial  
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, June 21, 2017

Partial Correction  
1 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X  
MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:  
NORTH STAIRWELL: BASEMENT LEVEL 1ST LAYER @ WELL FACE +  
PRE-ROCK AT BACKSIDE JOIST BAYS; FIRST FLOOR 1ST LAYER @  
WELL FACE + PRE-ROCK AT BACKSIDE JOIST BAYS;  
SOUTH STAIRWELL: FIRST FLOOR 1ST LAYER @ WELL FACE +  
PRE-ROCK AT BACKSIDE JOIST BAYS;

**Comments:**