

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Thursday, June 22, 2017
Partial Correction 2 Misc		OK TO COVER WHEN READY FRAMING OF WALLS AND CEILINGS + SYSTEMS TO BE ENCLOSED AT SPACES: 204; 205; 211; 212; 214; 215; 217; 222; 223; 224; 214;[208; 304; 305; 310; 311; 312; 314; 315; 317; 322; 323; [324;	
Partial Correction 3 Misc		OK TO INSTALL GWB CEILING AND WALLS AT CORRIDOR SPACES: 201; 216; 219; 221; 225; 301; 316; 324; 325;	
Partial Correction 4 Misc		OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT ELEVATOR LOBBIES AT: 2ND FLR; 3RD FLR;	
Rated Assembly Inspection	John Borns	Partial	Thursday, June 22, 2017
Partial Correction 1 Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS AT: 201; 216; 219; 221;	
Partial Correction 2 Misc		OK TO COVER WHEN READY 5/8" TYPE X GWB AT UNIT FACE OF STAIRWELL WALLS AT: 214;	
Partial Correction			

3 Misc OK TO COVER WHEN READY FRAMING + SHAFT LINER BOARD AT STAIRWELLS -- WELL SIDE + UNIT SIDE AT: 102; 202; 203; 213; 302; 303; 313; 314;

Partial Correction

4 Misc OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS AND WALLS AT:
204; 205; 211; 215; 217; 222;223; 224; [**212; 214;**

[314 GWB ABOVE CEILING AT STAIRWELL WALL

Comments: