



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20170499 Date: June 23, 2017  
Project Title: BROW THREADING Applicant:  
Location: 910 NW BLUE PKWY, Unit:D, LEES KANSAS CITY FIRE AND SECURITY LLC  
SUMMIT, MO 64086 901 E LOULA ST  
Type of Work: OLATHE, KS 66061  
Occupancy Group: Primary: (913) 780-5237  
Description: TENANT FINISH FOR PERSONAL CARE SALON - FACIALS, WAXING, ETC

\*\*\* NEW CONTACT PERSON- JUAN JUAREZ-816-738-4019. PRIMARY CONTACT POINT FOR JOB.

Construction Type: Type IIB (Unprotected)  
Map Page: 195A

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.  
ACTION REQUIRED:(information purposes)  
Acceptance testing of the system modifications will be required prior to the final occupancy inspection. to schedule a test contact the fire department at 816-969-1300.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**