

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170201, Building Permit - Residential

Address: 2233 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822235 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822237 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822231 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Monday, June 26, 2017

**Corrective Action Required**

1	Misc	inspection denied for lack of proper erosion control .
---	------	--

<b>Erosion Control</b>	Mark Harding	Failed	Monday, June 26, 2017
------------------------	--------------	--------	-----------------------

**Corrective Action Required**

1	Misc	inspections denied for lack of erosion control. no further inspections untill all lots have approved erosion contro and storm entrances are clean and protected.
---	------	---

**Comments:**