

Temporary Certificate of Occupancy

Permit #: PRCOM20170850
Address: 236 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Inspected On: Tuesday, June 27, 2017
Inspected By: John Borns
Expiration Date: 7/27/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Tuesday, June 27, 2017

LIGHTED SIGN YET TO BE INSTALLED.

NEC 600.4 ELECTRIC SIGN MARKINGS: SIGNS AND OUTSIDE LIGHTING SYSTEMS SHALL BE SHOP-LABELED WITH LISTING, MANUFACTURER'S NAME, TRADEMARK, OR OTHER MEANS OF IDENTIFICATION; AND INPUT VOLTAGE AND CURRENT RATING.