

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160836, Building Permit - Commercial  
Address: 2641 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, June 27, 2017

### Corrective Action Required

1	Misc	-SUBMIT NEW ELECTRICAL SERVICE DIAGRAM THAT INCLUDES THE GENERATOR AND TRANSFER SWITCH/SERVICE DISCONNECT TO THE CITY FOR APPROVAL -PROVIDE MIN. 3 FT WORKING CLEARANCE IN FRONT OF THE SERVICE EQUIPMENTS -INSTALL EQUIPMENT GROUNDING CONDUCTOR FOR EACH PARALLEL FEEDER RACEWAY SIZED PER 250.122 -INSTALL BUSHINGS
---	------	---

### Comments: