

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161761, Building Permit - Commercial
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, June 27, 2017

Partial Correction
1 Misc

RATED ASSEMBLIES AT STAIRWELLS:
OK TO COVER AT **SOUTH STAIRWELL:**
BASEMENT: 1ST & 2ND LAYER 5/8" TYPE X MOLD-TOUGH GWB
INCLUDING PRE-ROCK BACKSIDE JOIST BAYS;
FIRST FLR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB
INCLUDING PRE-ROCK BACKSIDE JOIST BAYS;

Partial Correction
2 Misc

RATED ASSEMBLIES AT ELEVATOR SHAFT:
BASEMENT: 1ST & 2ND LAYERS PRE-ROCK AT BACKSIDE JOIST BAYS

Rough Framing Inspection - Commercial	John Borns	Partial	Tuesday, June 27, 2017
--	------------	---------	------------------------

Partial Correction
1 Misc

SHEAR WALLS AT STAIRWELLS:
SOUTH STAIR: 1ST FLOOR;
NORTH STAIR: 1ST FLOOR;

Comments: