PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162554, Building Permit - Residential Address: 1328 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Failed Wednesday, June 28, 2017

Codes Residential

Corrective Action Required

. Misc -OBTAIN LAWN SPRINKLER PERMIT

-EXPOSE WATER METER. MAKE SURE THE DISTANCE FROM TOP

OF METER TO LID IS 14"-18"

-EXPOSE THE SEWER TRACER WIRE ACCESS BOX

-FINAL GRADE, SOD, SPLASHBLOCKS

-SEAL EXTERIOR: LIGHTS AD ALL PENETRATIONS

-CLOSE EXTERIOR WALL OPENING OUTSIDE MASTER BED -MOVE THE AC DISCONNECT TO LOCATION THAT ALLOWS

PROPER WORKING CLEARANCE

-RECEPTACLE AT LAUNDRY SINK NOT GFCI

-THE CEILING LUMINAIRES IN MASTER CLOSET SHALL BE ENCLOSED-LAMP TYPE. OPEN CAN LIGHT NOT ALLOWED

-GARAGE IS NOT ACCESSIBLE AT THIS TIME

-INSTALL FACE PLATES THROUGHOUT

-BOND SWITCHES THROUGHOUT

-COMPLETE INSTALLATION OF FLOOR RECEPTACLES. INSTALL BOX EXTENSIONS FOR FLOOR RECEPTACLE BOXES NOT FLUSHED WITH CARPET

-COMPLETE GAS CONNECTION TO COOKTOP

-INSTALL WATER HAMMERING ARRESTOR FOR DISH WASHER

AND CLOTHES WASHER

-DECK RECEPTACLE IS NOT GFCI

-INSTALL BREAKER LOCKS FOR OVEN AND WATER HEATER

-INSTALL SWITCH WITHIN SIGHT FOR THE BASEMENT BATHFAN

-PROVIDE COMBUSTION AIR OPENINGS FOR MECH SPACE PER

CODE

-INSTALL SEWER CLEAN OUT PLUG

- -STOOP SUSPENDED SLAB WAS NOT INSPECTED
- -SECURE FURNACE AND WATER HEATER LFNC RACEWAY PER CODE
- -REMOVE ALL FOUNDATION WALL TIES
- -INSTALL ADDITIONAL RECEPTACLE (GFCI) IN MECH SPACE(IN ADDITION TO THE DEDICATED RECEPTACLE)
- -PROVIDE ACCESS TO UFER GROUNDING CONNECTION
- -EXTERIOR DOOR: INSTALL SECURITY STRIKE PLATE WITH 4-3" SCREWS; INSTALL 2-3" SCREWS FOR EACH HINGE

Comments: