

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRCOM20161058, Building Permit - Commercial
WATER UTILITIES FACILITY (HAMBLEN RD)
Address: 1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	Brice Lawson	Partial	Tuesday, June 27, 2017

Corrective Action Required

- 1 Brice Lawson 06/27/2017 3:08 PM
The domestic water service including meter has been installed from the tie-in at the 6" water main extension to the building riser. The 1" copper line has been installed to the wash bay. The 1.5" copper irrigation service line has been installed from the 4" C900 over to the water meter for the irrigation line. All bacterial tests for each of these lines have passed and the lines have been put into service.

***The irrigation line was only installed and inspected up to the inlet side of the meter.

Comments: