

CODES ADMINISTRATION

PLAN REVIEW CONDITIONS

June 28, 2017

MAKLIN CONSTRUCTION LLC
1114 W 7TH STREET
EDGERTON, KS 66021

Permit No: PRCOM20171923
Project Title: WALLY'S GRILL & DRAFTHOUSE
Project Address: 837 SW LEMANS LN, LEES SUMMIT, MO 64082
Parcel Number: 70920019500000000
Location: RAINTREE LAKE VILLAGE LOTS 1-6 & TR A ---LOT 6
Type of Work: CHANGE OF TENANT
Occupancy Group: ASSEMBLY FOR FOOD AND DRINK INC BARS, RESTAURANTS, BANQUET HALLS
Description: TENANT FINISH FOR NEW RESTAURANT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 1004.3- Posting of occupant load. Every room or space that is an assembly occupancy shall have the occupant load of the room or space posted in a conspicuous place, near the main exit or exit access doorway from the room or space. Posted signs shall be of an approved legible permanent design and shall be maintained by the owner or authorized agent.

ACTION REQUIRED:(verified at inspection)

Post the occupant load of 102 in the dining area

2. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED:(information purposes)

Have the fire alarm system contractor provide shop drawings to the fire department for approval of any modifications to be done to the fire alarm system.

3. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

ACTION REQUIRED: (verified at inspection)

If not already existing post the numeric address of 837 on the exterior of all the doors leading into the business. Address shall be readable from the roadway.

4. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED: (information purposes)

Have the Fire sprinkler system contractor provide shop drawings to the fire department for approval of any modifications to be done to the fire sprinkler system.

5. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED: (information purposes)

Acceptance testing of any modifications done to the fire alarm system is required prior to the final occupancy inspection. To schedule a test contact the fire department at 816-969-1300.

6. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(verified at inspection)

The fire sprinkler system, type-I hood and hood suppression system shall be current with all required cleaning, servicing and maintenance. Current service tags shall be posted on the sprinkler sysemt riser, the type-I hood and a service tag on the type-I hood suppression systems manual pull station.

7. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

ACTION REQUIRED:(verified at inspection)

If not already existing provide. one 2A-10BC fire extinguisher to be mounted around the bar area, or close to an exit. Provide one K-class fire extinguisher to be mounted under or close to the manual pull station for the hood system.

8. Exit lights and emergency lighting

ACTION REQUIRED:(verified at inspection)

All exit lights and emergency lighting shall illuminate on AC power and DC power.

9. Door operations

ACTION REQUIRED: No keyed locks on the egress side of an exit (verified at inspection)

[B] 1008.1.9 Door operations.

Except as specifically permitted by this section egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

Building Plan Review

Reviewed By: Joe Frogge

Approved with Conditions

2. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

4. For the Health Department inspection contact Deb Sees with the Jackson County Public Works Department, Environmental Health Division at (816) 847-7070. Health Department approval is required prior to receiving any type of

Occupancy from the City of Lee's Summit.

Action required: Comment is for informational purposes.

Licensed ContractorsReviewed By: Joe FroggeApproved

- ☒ Approved to issue per the listed conditions.
- ☐ Do not issue per the listed conditions.
- ☐ Approved to construct foundation only per the listed conditions.
- ☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of ApplicantDate

Print Applicant NameCompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.