

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160939, Building Permit - Commercial  
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Khanh Nguyen	Partial	Wednesday, June 28, 2017

Partial Correction  
1 Misc

RATED CEILING ASSY OK BELOW:  
-ZONE A CORRIDOR&BATH ONLY-2ND LAYER OK  
-ZONE C CORRIDOR&BATH ONLY-2ND LAYER OK  
-ZONE B: ALL AREAS EXCEPT HEARTH&GATHERING&KITCHEN-1ST  
LAYER OK

**Comments:**