

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170201, Building Permit - Residential

Address: 2233 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822235 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822237 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822231 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Wednesday, June 28, 2017
Rated Assembly Inspection	Mark Harding	Passed	Wednesday, June 28, 2017
All Rough Inspection - Residential	Mark Harding	Failed	Wednesday, June 28, 2017

Corrective Action Required

1 Misc

install plumbing protection plates where required.

connect bath fans

Comments: