

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161177, Building Permit - Commercial  
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Wednesday, June 28, 2017
Partial Correction 1 Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS AT: 201; 216; 219; 221;	
Partial Correction 2 Misc		OK TO COVER WHEN READY 5/8" TYPE X GWB AT UNIT FACE OF STAIRWELL WALLS AT: 214; 314 GWB ABOVE CEILING ONLY	
Partial Correction 3 Misc		OK TO COVER WHEN READY FRAMING + SHAFT LINER BOARD AT STAIRWELLS -- WELL SIDE + UNIT SIDE AT: 102; 202; 203; 213; 302; 303; 313; 314;	
Partial Correction 4 Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS AND WALLS AT: 204; 205; 211; 212; 214; 215; 217; 222; 223; 224; <b>[208; CORR 201/216;</b>  <b>[310; 312;</b>	
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Wednesday, June 28, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY FRAMING OF WALLS AND CEILINGS + SYSTEMS TO BE ENCLOSED AT SPACES:	

204; 205; 206; 207; 208; 211; 212; 214; 215; 217; 222; 223; 224;  
214; [209

304; 305; 306; 307; 308; 310; 311; 312; 314; 315; 317; 322; 323;  
324;

412; 414; [**411; 415;**

Partial Correction  
2 Misc

OK TO INSTALL GWB CEILING AND WALLS AT CORRIDOR SPACES:  
201; 216; 219; 221; 225;  
301; 316; 324; [**ELEVATOR LOBBY 325;**  
401; 416;

Partial Correction  
3 Misc

OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS  
AT ELEVATOR LOBBIES AT: 2ND FLR; 3RD FLR;

**Comments:**