

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20162127, Building Permit - Residential  
Address: 320 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Dale Carter	Failed	Wednesday, June 28, 2017

### Corrective Action Required

- |   |      |   |
|---|------|---|
| 1 | Misc | <ol style="list-style-type: none"><li>1. Complete electrical installation in basement.</li><li>2. Address illumination fixture shall not allow ready access to light bulb.</li><li>3. The circuit breaker serving the downstairs oven is not labelled and should be equipped with a LO/TO bracket.</li><li>4. Secure yokes of electric receptacles throughout basement and dining room.</li><li>5. Patch drywall around electric receptacle in Dining Room.</li></ol> |
|---|------|---|

### Comments: