

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, June 29, 2017
Partial Correction 2 Misc		OK TO COVER WHEN READY 5/8" TYPE X GWB AT UNIT FACE OF STAIRWELL WALLS AT: 214; 314 GWB ABOVE CEILING ONLY	
Partial Correction 3 Misc		OK TO COVER WHEN READY FRAMING + SHAFT LINER BOARD AT STAIRWELLS -- WELL SIDE + UNIT SIDE AT: 102; 202; 203; 213; 302; 303; 313; 314;	
Partial Correction 4 Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB CEILINGS AND WALLS AT: CEILING ONLY AT 201; 204; 205; 208; 211; 212; 214; 215; CORR 216; 217; 222; 223; 224; [206; 207; 209; CORR 219; 221; 310; 312;	
All Rough Inspection - Commercial	John Borns	Partial	Thursday, June 29, 2017
Partial Correction 1 Misc		OK TO COVER WHEN READY FRAMING OF WALLS AND CEILINGS + SYSTEMS TO BE ENCLOSED AT SPACES:	

204; 205; 206; 207; 208; 209; 211; 212; 214; 215; 217; 222; 223;
224; 214; **[218];**

304; 305; 306; 307; 308; 310; 311; 312; 314; 315; 317; 322; 323;
324;

411; 412; 414; 415; **[417];**

Partial Correction
2 Misc

OK TO INSTALL GWB CEILING AND WALLS AT CORRIDOR SPACES:
201; 216; 219; 221; 225;
301; 316; 324; ELEVATOR LOBBY 325;
401; 416;

Partial Correction
3 Misc

OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS
AT ELEVATOR LOBBIES AT: 2ND FLR; 3RD FLR;

Comments: