

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170197, Building Permit - Residential

Address: 2223 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822225 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822227 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822221 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Passed	Thursday, June 29, 2017
Electrical Service Inspection - Residential	Mark Harding	Passed	Thursday, June 29, 2017
All Rough Inspection - Residential	Mark Harding	Failed	Thursday, June 29, 2017

Corrective Action Required

1	Misc	check plumbing protection plates at all unit (top and bottom plates -notched studs for bath vent at 1st floor mstr -2125 firestop dryer vents 1st floor -2123,2125 check laundry drain for 4" between trap and drain -2123 firestop heat duct to 2nd floor over kitchen -2123 seal ridge at firewall -2121 support 3" dwv over kitchen -2121 complete roof support and blocking at front vbedroom rafters. support flat ceiling joist in 1/2 bath. ok to insulate do not cover items
---	------	--

Comments: