

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160125, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, Unit:330, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Passed	Thursday, June 29, 2017

Comments:

**ENSURE OPENINGS IN CORRIDOR SMOKE WALL ARE SEALED.
NON-COMPLIANT MC CABLE AT SW SPACE TO BE REMOVED.
OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS.**